

商洛杨峪河 110 千伏输变电工程
环境影响报告表

建设单位: 国网陕西省电力有限公司商洛供电公司

评价单位: 核工业二〇三研究所

编制日期: 二〇二四年二月

建设项目环境影响报告表

项目名称：商洛杨峪河 110 千伏输变电工程

建设单位（盖章）：国网陕西省电力有限公司

商洛供电公司


编制单位：核工业二〇三研究所

编制日期：2024 年 2 月

一、建设项目基本情况


	110		
			15109271703
	110kV 109 52 11.238 E 33	110kV 52 35.960 N	2 50MVA
	~ 52 59.80 N	110kV 109 52 12.146 E 33	109 52 28.908 E 33 52 36.008 N
	~ 52 17.986 N	110kV 109 52 12.146 E 33	109 53 35.032 E 33 52 36.008 N
	~ 52 17.344 N	35kV 109 52 12.146 E 33	109 51 53.992 E 33 52 36.008 N
	330kV 110kV	110kV	
	—161	m ² / km	5918m ² 3080m ²
	■ □ □ □		■ □ □ □
	/	/	/
	8090		48
%	0.59		12
	■ □ _____		
	1		
	HJ 24-2020		

	<p>2</p> <p>HJ 24-2020 B B.2.1</p>
	1626SL2100V
	/
	<p>1</p> <p>2024</p> <p>2</p> <p>2</p> <p>110kV</p> <p>110kV 35kV 10kV</p> <p>110kV 1 110kV</p> <p>110kV 110kV 110kV</p> <p>2 330kV 110kV</p>



1

110kV




2

3

1-1

1-1			
1	“ ”	1	
		2	
		3
		4	“ ”
		2025
		2035
			“ ”
2		2025	
3	2023~2027	

		DB61/1078-2017)				
4						
1-2						
1-2						
2021 108				“ ” 4		
2020 11						
1-2						
序号	区县	环境 管控 单元 名称	单 元 要 素 属 性	管 控 单 元 分 类	管 控 要 求	面 积 (m ²)
1					1. 5.6	4045
					1. 5.6	



日期: 2024/1/3

0 1,000 2,000 4,000 m

- 图例
- 执行控制
 - 重点管控
 - 一般管控
 - 监测点 1
 - 重点管控
 - 执行控制

5				
1-3				
1-3				
	39	>	<	2020
		GB 8702-2014		
			GB3096-2008	
	4			
	110			
)	2018	213	(
			2021	11 18
6				
1-4				
		2000m		
	1000m		1.	2000m
	500m			
			1000m	
			500m	2.
				3.
				4.
	36	51		
		140		
	13	0.81 km ²		
		14%	1584.98km ²	96
				5029


			3.		
				4.	
	39	335 3500	100m		
	3.25 km ² 56%	430	998.97km ²	237	
				96103	
			1.		
				2.	
			3.		
				4.	
	1-4				

	<p>1500 2000</p>		
	<p>1-4</p>		
		<p>44</p>	
	<p>1-4</p>		
<p>7</p>	<p>1-5</p>		

	330kV	110kV	
	GB 12348	GB 3096	
	1	2	
	GB 12348		GB
	1	12348	
	8		

--	--

二、建设内容


	110		4
		1.6	3
	7.2	G242	2.5
	~	π	~
	110kV	110kV	35kV
	2-1		
			
	2-1		
1			
		10MW	
10kV	2	4.96MW	3.4MW

					10kV	
	35					
	28MW				110kV	
5	10kV		10kV			3
	2			10kV	N-1	
	10					
						110kV
	2					
		110kV				
		330kV	110kV			
		110kV				
	~			110kV		
	~			110kV		
	~			35kV		
	~			110kV		
			2	0.6km		
0.55km						
	~			110kV		
			2	2.2km		
0.8km						
	~			35kV		
			2	0.9km		
0.08km						
					110kV	1

	3		330kV	110kV
	1	110kV	3	2 110kV
	1	110kV		1 110kV
		110kV		2-2
	2-1			
		2-1		
			35kV	10kV
		110kV	4 110kV	330kV ~ ~ 110kV 300mm ²
			2×50MVA	
		3×50MVA 110±8×1.25%/10.5kV		
	110kV	GIS		
	10kV			
		110kV	35kV	
		10kV		
		110kV	5	4
		35kV	6	4
		10kV	24	16
			1	3.6Mvar
			1	4.8Mvar
		10kV	1	
			0.5538hm	8.307
		6.055		
				4m ³
		110kV GIS	10kV	
			4m ³	
110kV				

				1			30m ³
~ 110kV			110kV	2	0.6km	1.75km	110kV 0.55km
			300mm ²				
			JL3/G1A-300/40				
			2	OPGW			1
			35kV OPGW	OPGW	1	LGJ-150/25	GJ-80
			6				
~ 110kV			110kV	2	2.2km	5.2km	110kV 0.8km
			300mm ²				
			JL3/G1A-300/40				
			2	OPGW			1
			35kV OPGW	OPGW	1	LGJ-150/25	GJ-80
			9				
~ 35kV			35kV	2	0.9km	1.88km	35kV 0.08km
			150mm ²	3	240mm ²		
			LGJ-150/25				
			OPGW				
			4				
			80m ²				
330kV 110kV			35kV			240mm	
			YJV22-26/35KV-3	240mm ²		80m	
			330kV	6		2 240MVA 110kV	330kV
					10		330kV
			GIS				110kV

		GIS			
		1	1	110kV	3 110kV
		2	110kV	110kV	
		2	1	110kV	
110kV		1 110kV			
	~	110kV			
	0.55km	48	OPGW	2 0.6km	330kV ~
	~	110kV			
	0.8km	48	OPGW	2 2.2km	
	~	35kV			
				2 0.9km	24 OPGW
				0.08km	24
				~	~



2-2

3

3.1 110kV

110kV 1 GIS 2×50MVA

110±8×1.25%/10.5kV

7.2km 0.5538hm 8.307 6.055

2-3



2-3 110kV

110kV 35kV 10kV

④

1 3.6Mvar 1 4.8Mvar

	⑤								
		10kV		1					
		4m ³							
		110kV GIS	10kV						
		110kV							
	3.2	~		110kV					
		110kV		1.75km	110kV				
2	0.6km		0.55km		300mm ²				
		JL3/G1A-300/40							
		2		OPGW				1	
	OPGW		1	GJ-80					
	35kV		LGJ-150/25					OPGW	
		330kV	~	110kV			30~31#	~	
			110kV	31#	125		1	30#	
	300	1							
								110kV	
		~		110kV					

		110kV		5.2km		110kV	
2	2.2km		0.8km		300mm ²		
		JL3/G1A-300/40					
		2		OPGW		1	
OPGW			1	GJ-80			
35kV			LGJ-150/25			OPGW	
		~	110kV	12~13#			
						110kV	
		~				35kV	
		35kV		1.88km	35kV		2
0.9km			0.08km		150mm ²	3	240mm ²
		LGJ-150/25					
		1		OPGW			
		35kV	20#	35kV			19#
35kV		17.7		1			
					110kV		35kV
					2-2		

2-2

			/		(m)	(m)	()	m	
110kV	~	S110-DC22D	2	ZC2	500	800	0	18	1
		S110-DC22S	2	JC1	500	800	0-30	18	1
		S110-DC22S	2	JC2	500	800	30-60	21	1
		S110-DC22S	2	JC3	500	800	60-90	21	1
		S110-DC22S	2	JD	300	500	0-90	21	1
		S110-DC22S	2	ZC3	600	800	0	18	1
110kV	~	S110-DC22D	1	ZC2	450	650	0	27	3
		S110-DC22S	1	JC1	500	800	0-30	18	1
		S110-DC22S	1	JC2	500	800	30-60	21	1
		S110-DC22S	1	JC3	500	800	60-90	21	2
		S110-DC22S	2	JD	300	500	0-90	21	2
35kV	~	S35-AD22S	2	J1	300	450	0-20	21	1
		S35-AD22S	2	J3	300	450	40-60	21	1
		S35-AD22S	2	J4	300	450	60-90	21	1
		S110-DB21GS	2	JG4	150	200	60-90	21	1

[2016]413

[2016]777

3

~

35kV

2 4

0.08km

0.03km 35kV

2 0.08km

YJV22-26/35KV-3 240mm²

430A

26.067MVA


1800

2 1


0.13km

2-3


2-3



台阶基础 G****



现浇钢筋混凝土挖孔桩基础 WK****



现浇钢筋混凝土灌注桩基础

1

110kV

110kV

35kV 10kV

SN-110-A1-2

110kV

110kV

35kV 10kV

110kV

35kV 10kV

10kV

10kV

110kV

110kV

110kV

1#

35kV

3# 10kV3#

35kV

1#

			1				
	~			110kV			
		330kV	~		110kV		30~31#
~			110kV		31#	125	1
30#	300	1					
							110kV
	~			110kV			
		~	110kV		12~13#		
						110kV	
	~			35kV			
	35kV	20#	35kV				19#
35kV		17.7	1				
				110kV			35kV
			2				

2

20m²

380m²

110kV

5538m²

5918m²

40m²

19

760m²

4

500m²

2000m²

2.0m×2.1m

80m

1m

4m

320m²


3080m²

2-4

2-4


m²


		280	100	/	380	
	110kV	5200	/	338	5538	
		300	/	460	760	3080
		500	/	1500	2000	
		120	/	200	320	
		6400	100	2498	8998	



--	--

三、生态环境现状、保护目标及评价标准






3-1



3-2



3-3

3-2	3-3	3-4							
3-2									
	HS5628A	HS6020 型							
	815-02	999-03							
	30~130dB (A) , 35~130dB (C)	/							
	ZS20230551J	ZS20230556J							
	2023.3.16 2024.3.15	2023.3.17 2024.3.16							
3-3									
		m/s		dB(A)					
2024.1.8		3.9		93.8	93.8				
		3.6		93.8	93.8				
2024.1.9		3.5		93.8	93.8				
		3.6		93.8	93.8				
3-4			dB A						
		1 8 dB(A)		1 9 dB(A)		dB(A)			
1	变电站拟建地中心	36	35	36	36	60	50		
2	银明村(拟建站北90m)	38	36	39	37	55	45		
3	银明村(拟建站南78m)	39	36	38	36	55	45		
4	耿家源 1	38	35	38	36	55	45		
5	耿家源 2	37	36	37	37	55	45		
6	耿家源 3	39	37	40	37	55	45		
7	仓库	38	37	38	35	60	50		
GB3096-2008		1	2						

<p>1</p> <p>330kV 2012</p> <p>110kV</p> <p>2</p>	<p>330kV 110kV</p> <p>110kV 80</p> <p>110kV</p>																															
<p>1</p> <p>110kV</p>	<p>3-5</p> <p>3-5</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 5%;"></td> <td style="width: 20%;"></td> <td style="width: 20%;"></td> <td style="width: 55%; text-align: center;">/</td> </tr> <tr> <td style="text-align: center;">1</td> <td rowspan="3" style="text-align: center; vertical-align: middle;">110kV</td> <td></td> <td style="text-align: center;">30m</td> </tr> <tr> <td style="text-align: center;">2</td> <td></td> <td style="text-align: center;">200m</td> </tr> <tr> <td style="text-align: center;">3</td> <td></td> <td style="text-align: center;">500m</td> </tr> <tr> <td style="text-align: center;">4</td> <td rowspan="4" style="text-align: center; vertical-align: middle;">110kV</td> <td></td> <td style="text-align: center;">30m</td> </tr> <tr> <td style="text-align: center;">5</td> <td></td> <td style="text-align: center;">30m</td> </tr> <tr> <td style="text-align: center;">6</td> <td></td> <td style="text-align: center;">5m</td> </tr> <tr> <td></td> <td></td> <td style="text-align: center;">300m</td> </tr> <tr> <td></td> <td></td> <td></td> <td style="text-align: center;">300m</td> </tr> </table> <p>2</p> <p>110kV 4</p> <p>110kV 3 2</p> <p>3-6 3-4~ 3-6</p>				/	1	110kV		30m	2		200m	3		500m	4	110kV		30m	5		30m	6		5m			300m				300m
			/																													
1	110kV		30m																													
2			200m																													
3			500m																													
4	110kV		30m																													
5			30m																													
6			5m																													
			300m																													
			300m																													

3-6

								/m	
				/m	/m				
1	106m		N	/	/	3	2	9	GB3096-2008 1
2	90m		N	/	/	4	2	9	
3	78m		S	/	/	3	2	9	GB3096-2008 1
4	178m		S	/	/	2	2	9	GB3096-2008 1
5	1		NW	2	14	4	2	9	GB8702-2014 GB3096-2008 1
6	2		SE	25	14	3	2	9	
7			W	0	14	0		7	GB8702-2014



3-4

110kV



3-5



3-6



106m



90m



78m



178m



1



2



3-7

1

GB 8702-2014

1

4kV/m

100μT

50Hz

10kV/m

GB/T15190-2014

3-7

3-7

1	55	45	dB A	
2	60	50	dB A	110kV

2

GB8702-2014

1

4kV/m

100μT

50Hz

10kV/m

DB61/1078-2017

1

3-8

DB61/1078-2017

				mg/m ³
1	TSP			≤0.8
2				≤0.7

GB12523-2011

70dB(A)


55dB(A)

GB12348-2008 1 2		3-9	
3-9		GB12523-2011	
		dB A	
GB12523-2011		70	55
3-10		GB12348-2008	
	dB A		
1	55	45	
2	60	50	
<p>GB18599-2020</p> <p>GB18597-2023</p> <p>GB16889-2008</p>			

四、生态环境影响分析

1


4-1



4-1

2

4-2




4-2

3

110kV

110kV

4-3



4-3

1

110kV

NO_x CO THC

2

110kV

13.3L/ ·d

12

30

143.64m³

3

110kV

HJ2034-2013

70 96dB A

4-1

4-1

		dB A	(m)
		90 95	5
		80 86	5
		80 88	5
		80 88	5
		88 95	5
		82 90	5
		83 88	5
		90 95	5
		90 95	5
		≤70	1
		90 96	5
		≤70	1

$$L_p = L_{p0} - 20 \lg(r/r_0)$$

L_p — dB(A)

L_{p0} — dB(A)

r — m

r_0 — m

4-2

4-2

	m															
	5	10	20	30	40	50	60	70	80	90	100	150	200	300	500	
	95	89	83	79	77	75	73	72	71	70	69	65	63	59	55	
	86	80	74	70	68	66	64	63	62	61	60	56	54	50	46	
	88	82	76	72	70	68	66	65	64	63	62	58	56	52	48	
	88	82	76	72	70	68	66	65	64	63	62	58	56	52	48	
	95	89	83	79	77	75	73	72	71	70	69	65	63	59	55	

	90	84	78	74	72	70	68	67	66	65	64	60	58	54	50
	88	82	76	72	70	68	66	65	64	63	62	58	56	52	48
	95	89	83	79	77	75	73	72	71	70	69	65	63	59	55
	95	89	83	79	77	75	73	72	71	70	69	65	63	59	55
	56	50	44	40	38	36	34	33	32	31	30	26	24	20	16
	82	76	70	66	64	62	60	59	58	57	56	52	50	46	42
	56	50	44	40	38	36	34	33	32	31	30	26	24	20	16

4-2

90m

GB12523-2011


90m

4

		30			
	4				
0.38kg/	·d		12		4.10t
5					
					110kV
			5918m ²		
		3080m ²			
	110kV				
	20m ²				

1


110kV



4-4

2

工频电磁场




4-5

3

110kV

4-6



4-6

1

HJ24-2020

110kV

110kV

4-3

4-3

	/m	/m	V/m	μ T
--	----	----	-----	---------

	14	-50 50	29.81 463.7	0.1408 1.858
	14	-50 50	12.37 338.4	0.037 1.113

80m

3

GB8072-2014

110kV

110kV

GB 8702-2014 50Hz

4000V/m

100 μ T

2

HJ24-2020

π 110kV

4-4

4-4

	π	110kV	110kV	
	110kV	110kV	110kV	
	110kV	110kV	110kV	

	JL/G1A-240/40	JL3/G1A-300/40	JL3/G1A-300/40	
	8.2m	14m	14m	

4-5

4-5

	π	110kV	XAZC-JC-2021-684	
			2021	9 23
			2.1m/s	
	II	17.58 A	-3.13	MW
	II	15.94 A	0.40	MW
		15# 16#	8.2m	

4-4 4-5

45 3 2009 6

π 240mm

4-6

4-6

		Leq	dB(A)
1	110kV		42
2		0m	40
3		5m	41
4		10m	40
5		15m	40
6		20m	39
7		25m	39
8		30m	41

π

39 42dB(A)

110kV

4-7

4-7

dB(A)

		/m			
1	耿家塬 1	2	40	55	45
2	耿家塬 2	26	40	55	45
3	仓库	0	40	60	50

110kV

GB3096-2008 1 2

110kV

HJ2.4-2021

a

c

(HJ2.4-2021)

a

		A _{div}	A _{atm}	A _{gr}
A _{bar}		A _{misc}		
$L_p(r) = L_p(r_0) + D_c - (A_{div} + A_{atm} + A_{gr} + A_{bar} + A_{misc})$				
L _p (r) —		dB		
L _p (r ₀) —	r ₀	dB		
D _c —				L _w
		dB		
A _{div} —		dB		
A _{atm} —		dB		
A _{gr} —		dB		
A _{bar} —		dB		
A _{misc} —		dB		

b

		A _{div}		
		A _{div} = 20lg(r/r ₀)		
A _{div} —		dB		
r —		m		
r ₀ —		m		
				L _{eqg}
$L_{eqg} = 10 \lg \left(\frac{1}{T} \sum_i t_i 10^{0.1 L_{Ai}} \right)$				
L _{eqg} —		dB		
T —		s		
t _i —	i	T	s	
L _{Ai} —	i		A	dB

L_{eq}

$$L_{eq} = 10 \lg (10^{0.1L_{eqg}} + 10^{0.1L_{eqb}})$$

L_{eq} dB

L_{eqg} dB

L_{eqb} dB

2

DL/T1518-2016 B B.1 1m 63.7dB(A)

B B.2 110kV~1000kV

5m 4m 3.5m

5m

4-8

4-8

	m			
2#	23.9	29.5	31.9	22.5
3#	34.9	29.5	20.9	22.5

TL 25dB(A)

HJ2.4-2021

1m

4-9

4

4-9

110kV

dB(A)

	49					60	50	0	0

		50					60	50	0	0
		42					60	50	0	0
		47					60	50	0	0
106m	1	13	41	39	41	39	60	50	0	0
	2	13	40	37	40	37	60	50	0	0
90m	1	11	39	37	39	36	60	50	0	0
	2	13	39	37	40	37	60	50	0	0
78m	1	6	39	36	39	36	60	50	0	0
	2	6	40	37	40	37	60	50	0	0
178m	1	6	39	37	39	37	60	50	0	0
	2	9	41	37	41	37	60	50	0	0

42 50dB(A)

GB12348-2008 2

39 41dB(A) 36 39dB(A)

GB3096-2008 2

3

4

110kV

110kV

4m³

5

110kV

110kV

3 5

	2021	HW31	900-052-31
		1	30m ³
			2021 HW08
		900-220-08	
	110kV	2×50MVA	50MVA
	18800kg	895kg/m ³	
	21.01m ³	110kV	30m ³
		DL/T5253-2018	
		C35	P6
	4.91×10 ⁻⁹ cm/s	40mm	
	35mm	C30	20mm 2cm
		1×10 ⁻¹⁰ cm/s	
		GB 18597-2023	
	6		
	7		
	1000mm	100mm	

1#	1	30m ³
	DL/T5253-2018	1
		GB18597-2023
		HJ 1113-2020
		4-10
	4-10	HJ 1113-2020
	HJ 1113-2020	
1		1-3
2		110kV
3		
4	0	110kV 0
5		2
6		
		HJ
	1113-2020	

110kV
110kV

[2023]186
[2023]204

[2023]148

[2023]92
[2023]209

五、主要生态环境保护措施

	1		
	16		2023~2027
		2023~2027	
	GB20891-2014		
	GB36886-2018		
		GB36886-2018	1
	DB61/1078-2017		

5

95%

3

	1
	2

	<p>3</p> <p>4</p> <p>110kV</p> <p>4m³</p> <p>110kV</p> <p>5</p> <p>110kV</p> <p>110kV</p> <p>6</p> <p>7</p> <p>110kV</p> <p>1</p> <p>30m³</p> <p>DL/T5253-2018</p>
	<p>1</p>

2

1

5-1

1				GB 8702-2014
2	A			GB3096-2008 1 2
				GB12348-2008 2

3

682 2017 10 1

5-2

	1		
	2		
	3		
	4	12348-2008 GB3096-2008	GB8702-2014 GB


		8090	48.0	
		0.59%		
		5-3		
				/
			GIS	
		—	—	4.0
				8.0
				/
				2.0
				15.0
		—	—	6.0
				—
				2.5
			30m ³	8.0
				0.5
				2.0
				48.0

六、生态环境保护措施监督检查清单

/				
/	/	/	/	/
		GB12523-2 011	GIS	GB 12348-2008 GB3096- 2008

		DB61/1078-2017		
				(GB8702-2014)
			30m ³ 1	

七、结论



110

电磁环境影响评价专题

建设单位： 国网陕西省电力有限公司商洛供电公司

评价单位： 核工业二〇三研究所

二〇二四年二月

1

110

1.1

110kV
330kV 110kV
110kV

~ 110kV
~ 110kV
~ 35kV

1.2

8090 48.0 0.59%

2

2015 1 1

2018 12 29

HJ 24-2020

GB 8702-2014

HJ 681-2013

HJ1113-2020

3

3.1

3.1-1

3.1-1

			V/m kV/m		V/m kV/m
			μT		μT

3.2

GB 8702-2014

3.1-2

	E V/m	H A/m	B μT	Seq(W/m ²)
0.025kHz 1.2kHz	200/f	4/f	5/f	—
1 f				
2 0.1MHz 300GHz		6		
3 100kHz			100kHz	
4				50Hz
10kV/m				

50Hz 3.2-1

4kV/m

100μT

50Hz

10kV/m

4

4.1

HJ 24-2020

4.1-1

4.1-1

	110kV	1		
		2	10m	
			10m	

10m

110kV

4.2

30m

30m

5m

5

5-1

5-1

				/m					
1	1		NW	2	14	4	2	9	GB 8702- 2014
2	2		SE	25	14	3	2	9	
3			W	0	14	0		7	

6

2024 1 8 0

HJ24-2020

HJ681-2013

6.1

6.2

6.2-1

		NBM-550	EHP-50F	
		FHP006-2018	FHP005-2018	
		5mV/m 100kV/m	0.3nT 10mT	
		XDdj2023-04837		
		2023.9.18~2024.9.17		

5

15s

1.5m

6.2-2

2024	1	8	11:10 17:20	6°C 36%

6.3

10

3-4

6.4

6.4-1

6.4-1

序号	监测点位描述		距地高度 m	电场强度 (V/m)		磁感应强度 (μT)	
				范围值	均值	范围值	均值
1#	变电站 拟建地	东站界	1.5	0.118~0.132	0.126	0.0007~0.0019	0.0014
2#		南站界	1.5	0.145~0.163	0.155	0.0008~0.0017	0.0013
3#		西站界	1.5	0.172~0.187	0.180	0.0008~0.0021	0.0016
4#		北站界	1.5	0.129~0.146	0.138	0.0007~0.0019	0.0013
5#	拟建线路工程 途经区域	拟建鹤西线线下	1.5	0.124~0.138	0.132	0.0008~0.0017	0.0012
6#		拟建商荆线线下	1.5	0.136~0.157	0.148	0.0007~0.0023	0.0017
7#		耿家塬 1	1.5	0.495~0.534	0.518	0.0009~0.0022	0.0015
8#		耿家塬 2	1.5	0.522~0.547	0.535	0.0010~0.0024	0.0017
9#		耿家塬 3	1.5	0.486~0.512	0.501	0.0011~0.0023	0.0017
10#		仓库	1.5	0.536~0.553	0.544	0.0008~0.0019	0.0014

110kV

0.118 0.187V/m

0.0007 0.0021μT

110kV

0.124 0.553V/m

0.0007 0.0024μT

GB8702-2014

7

HJ24-2020

110kV

110kV

7.1

7.1.1

HJ 24-2020

C

D

$$\begin{bmatrix} U_1 \\ U_2 \\ \vdots \\ U_m \end{bmatrix} = \begin{bmatrix} \lambda_{11} & \lambda_{12} & \cdots & \lambda_{1m} \\ \lambda_{21} & \lambda_{22} & \cdots & \lambda_{2m} \\ \vdots & & & \\ \lambda_{m1} & \lambda_{m2} & \cdots & \lambda_{mm} \end{bmatrix} \begin{bmatrix} Q_1 \\ Q_2 \\ \vdots \\ Q_m \end{bmatrix}$$

U_i —

Q_i —

λ_{ij} — n n

[U]

1.05

[λ]

x y E_x E_y

$$E_x = \frac{1}{2\pi\epsilon_0} \sum_{i=1}^m Q_i \left(\frac{x-x_i}{L_i^2} - \frac{x-x_i}{(L'_i)^2} \right)$$

$$E_y = \frac{1}{2\pi\epsilon_0} \sum_{i=1}^m Q_i \left(\frac{y-y_i}{L_i^2} - \frac{y+y_i}{(L'_i)^2} \right)$$

x_i y_i — i i=1 2 ... m

m—

ϵ_0 —

L_i L'_i — I

$$H = \frac{I}{2\pi\sqrt{h^2 + L^2}} \quad (\text{A/m})$$

I— i
h—
L—

(A/m) (mT)

$$B = \mu_0 H$$

B— T
H— H
 μ_0 —

$$\mu_0 = 4\pi \times 10^{-7} \text{H/m}$$

7.1.2

JL3/G1A-300/40

270A

HJ 24-2020

110-DC22D-ZC2

14m

110-DC22S-ZC3

14m

7.1-1

7.1-2


7.1-1

7.1-1 110kV

	110-DC22D-ZC2	110-DC22S-ZC3
	JL3/G1A-300/40	
A	270	
kV	110	
mm	23.9	
	14m	14m

7.1-2

			X	Y
A	110-DC22D-ZC2	14.0m	0	18.0
B			-3.3	14.0
C			3.3	14.0
A1	110-DC22S-ZC3	14.0m	3.38	14
B1			3.7	18
C1			3.28	22
A2			-3.28	22
B2			-3.7	18
C2			-3.28	14



7.1-1

7.1.3


110-DC22D-ZC2

7.1-3


7.1-3 110-DC22D-ZC2

(m)	110-DC22D-ZC2	
	V/m	14.0m μT
0	371.85	1.313
1	378.04	1.270
2	394.47	1.457
3	416.09	1.788
4	437.30	1.858
5	453.75	1.785
6	462.85	1.703
7	463.70	1.615
8	456.64	1.523
9	442.81	1.429
10	423.72	1.337
11	400.97	1.247
12	376.01	1.161
13	350.08	1.080
14	324.14	1.004
15	298.90	0.9331
16	274.84	0.8674
17	252.26	0.8068
18	231.30	0.7510
19	212.02	0.6998
20	194.41	0.6528
21	178.38	0.6098
22	163.86	0.5703
23	150.72	0.5340
24	138.85	0.5008
25	128.14	0.4702
26	118.47	0.4422
27	109.73	0.4163
28	101.83	0.3925
29	94.68	0.3705
30	88.21	0.3502
31	82.33	0.3315
32	76.99	0.3141
33	72.12	0.2980
34	67.69	0.2830
35	63.63	0.2690
36	59.92	0.2561

(m)	110-DC22D-ZC2	
	V/m	14.0m μT
37	56.52	0.2440
38	53.39	0.2327
39	50.51	0.2221
40	47.85	0.2122
41	45.40	0.2030
42	43.12	0.1943
43	41.02	0.1861
44	39.06	0.1785
45	37.24	0.1712
46	35.55	0.1644
47	33.97	0.1580
48	32.49	0.1520
49	31.11	0.1463
50	29.81	0.1408



7.1-2 110-DC22D-ZC2



7.1-3 110-DC22D-ZC2

110-DC22D-ZC2

14.0m

-50m 50m

29.81 463.7V/m

7m

50m

0.1408 1.858μT

4m

50m


110-DC22S-ZC3

7.1-4


7.1-4 110-DC22S-ZC3

110-DC22S-ZC3			14.0m		
(m)	V/m	μT	(m)	V/m	μT
-50	12.4	0.037	1	295.5	0.493
-49	12.6	0.040	2	306.1	0.744
-48	12.9	0.042	3	319.5	1.012
-47	13.1	0.044	4	331.3	1.113
-46	13.3	0.047	5	338.2	1.064
-45	13.6	0.050	6	338.3	1.008
-44	13.8	0.053	7	331.4	0.948
-43	14.0	0.056	8	317.9	0.886
-42	14.1	0.059	9	299.2	0.823
-41	14.3	0.063	10	276.7	0.760
-40	14.4	0.067	11	252.0	0.700

110-DC22S-ZC3			14.0m		
(m)	V/m	μT	(m)	V/m	μT
-39	14.5	0.072	12	226.5	0.642
-38	14.5	0.077	13	201.2	0.588
-37	14.6	0.082	14	176.9	0.537
-36	14.6	0.088	15	154.2	0.490
-35	14.5	0.094	16	133.4	0.448
-34	14.5	0.101	17	114.6	0.408
-33	14.5	0.108	18	97.90	0.373
-32	14.6	0.116	19	83.23	0.340
-31	14.9	0.125	20	70.47	0.311
-30	15.5	0.135	21	59.49	0.284
-29	16.4	0.146	22	50.13	0.260
-28	17.9	0.158	23	42.24	0.238
-27	20.2	0.171	24	35.68	0.219
-26	23.3	0.186	25	30.33	0.201
-25	27.4	0.202	26	26.05	0.185
-24	32.6	0.220	27	22.73	0.170
-23	38.9	0.239	28	20.24	0.157
-22	46.6	0.261	29	18.46	0.145
-21	55.8	0.285	30	17.23	0.134
-20	66.5	0.311	31	16.43	0.125
-19	79.0	0.341	32	15.93	0.116
-18	93.4	0.373	33	15.63	0.107
-17	109.8	0.408	34	15.44	0.100
-16	128.3	0.447	35	15.32	0.093
-15	148.8	0.490	36	15.23	0.087
-14	171.3	0.537	37	15.13	0.081
-13	195.4	0.587	38	15.03	0.076
-12	220.6	0.641	39	14.91	0.071
-11	246.1	0.698	40	14.77	0.066
-10	271.0	0.758	41	14.61	0.062
-9	293.8	0.820	42	14.43	0.059
-8	313.1	0.883	43	14.23	0.055
-7	327.3	0.946	44	14.01	0.052
-6	335.1	1.006	45	13.78	0.049
-5	335.9	1.061	46	13.54	0.046
-4	329.9	1.110	47	13.29	0.044
-3	318.9	1.054	48	13.03	0.041
-2	306.1	0.786	49	12.77	0.039
-1	295.6	0.527	50	12.51	0.037
0	291.6	0.381			



7.1-4 110-DC22S-ZC3



7.1-5 110-DC22S-ZC3

110-DC22S-ZC3

14.0m

-50m 50m

12.37 338.4V/m

6m

-50m

0.037 1.113μT

4m

-50m

4kV/m

4kV/m

7.1-6 7.1-7




图 7.1-6 工频电场强度 4kV/m 等值线分布图（单回路）




图 7.1-7 工频电场强度 4kV/m 等值线分布图（双回路）

7.1-6

4kV/m

12m~20m

-6~6m

4kV/m

12m~26.5m

-6~6m

4kV/m

12m

14m

7.1.4

~

110kV

110-DC22D-ZC2

7.1-5

7.1-5

	/m	/m	V/m	μT
1	1.5	2	453.7	1.785
2	1.5	25	94.68	0.3705
	1.5	0	416.1	1.788

94.68 453.7V/m

0.3705 1.788μT

GB8072-2014

7.2

7.2.1

110kV

110kV

7.2-1

	110kV	110kV
	110kV	110kV
	2×50MVA	2×50MVA
	GIS	AIS
110kV	4	4
	0.5538hm ²	0.68hm ²

7.2-1

110kV

7.2.2

7.2.3

HJ 681-2013

7.2.4

1

110kV

XDHJ/2019-021JC

2

2019 4 29

3

7.2-2

7.2-2

SEM-600	5mV/m 0.1nT	100kV/m 10mT	S-0177 G-0177	CEPRI-DC JZ -2019-008	2020 3 18
---------	----------------	-----------------	------------------	--------------------------	--------------

7.2.5

1

110kV

7.2-3

7.2-3

	P MW	Q MVar	A	kV
1	8.43	2.13	41.36	114.87
2	8.86	2.24	44.27	114.93

2

110kV

7.2-4


7.2-4

110kV		15.2 23.3℃	41.3 48.1%	0.2 0.6m/s
-------	--	------------	---------------	---------------

7.2.6

110kV

7.2-1



7.2-1 110kV

7.2.7

110kV

7.2-5

7.2-5

		V/m	V/m	μT	μT
1		13.27	4000	0.046	100
2		81.16		0.076	
3		99.87		0.082	
4		73.52		0.124	
5		41.97		0.213	



110kV

13.27

99.87V/m

0.046 0.213μT

GB8702-2014

4000V/m

100μT

110kV

GB 8702-2014

4000V/m

100μT

7.3

0.5m

3

8

GB8702-2014